

Group R1 Occupancies - Hotel Evacuation Diagram Requirements International Fire Code, 2003 edition

Section 408.8.1 requires that an evacuation diagram depicting two evacuation routes be posted on or immediately adjacent to every required egress door from each hotel room, motel or dormitory guestroom.

Typically would be a floor plan of the hotel which identifies the location of primary evacuation routes and exits, secondary evacuation routes, accessible egress routes, areas of refuge if applicable, manual fire alarm boxes, and portable fire extinguishers.

*Information provided by South Dakota Office of State Fire Marshall
December 2008*